

From: Andrew Windress
Sent: 31 July 2018 09:22
To: Gary Housden
Subject: RE: proposed conditions

Gary

I attach an annotated plan that shows the area that we would request is not restricted regarding outside storage. It would not be the whole area as vehicles would need to be able to manoeuvre through. The stacks would be as per the EA requirements that has set the parameters for the storage buildings, these are outlined below. There is already significant planting on the southern boundary in this location that would be retained to help screen the tyres.

`Environment Agency` Guidance `Fire Prevention Plans: Environmental permits`.

Stack Size (Max)

Volume:- 450 cubic metres
Height:- 4 metres
Length:- 20 metres
Width:- 20 metres

Separation Distance (Min)

6 metres between stacks.
6 metres between stacks and the site perimeter and any buildings.

Regards

Andrew

Andrew Windress
Director
ID Planning
9 York Place
Leeds
LS1 2DS